

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0065:101 Page 1 of 1

**CATEGORY:** Audible Signal Devices

**LISTEE:** Faraday Inc, 805 S. Maumee St., Tecumseh MI 49286  
Contact: Steve A. Blohm (517) 423-2111

**DESIGN:** Models 5910, 5920, 5930, 5940, 5950, 5960, 5970, 5980, 5990, 6020 and 6030 horns.

Models 6110, 6120, 6130, 6140, 6160 and 6190 for use with adapter plate 5003, 5004, 5005, 5006, 5008, 5510, 5511, 5512, 5513, 5514, 5515, 5516, 5517, 5518 horns.

Models 6113, 6114, 6115, 6163, 6164, 6165, \*6170 and \*6180 horns.

Models 6116, 6117, 6118, 6166, 6167, 6168 horns with or without suffix -W, -S, -D or -N.

\*Models 6174, 6178, 6184 and 6188 horn/strobes with or without suffix -E, -G, -J, -K, -L, -M, R, -T, -Y or -Z.

Refer to listee's data sheet for additional detailed product description and operational considerations.

**INSTALLATION:** In accordance with the listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name or registered trademark "FOS", model number, electrical rating and UL label.

**APPROVAL:** Listed as audible devices for use with separately listed compatible fire alarm control units. May be used with separately listed compatible strobes. Models 6110 and 6170\* are not approved for use with household fire warning system. Models may be used outdoors when used with Model 3014 or 3015 back box. If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1996 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

**NOTE:** Models with strobe lights for the hearing-impaired are not suitable for outdoor use.

\*Rev. 09-30-98



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager